



NOTES:

WATER METERS SHALL BE PURCHASED THROUGH THE CITY PURCHASE INCLUDES INSTALLATION.

INSTALL CONCRETE BLOCKING (4"x4"x 15 1/2" SOLID SLUMP BLOCK) UNDER ENTIRE UTILITY BOX PERIMETER.

BURIED PIPE AND FITTINGS SHALL BE WRAPPED WITH 8 MIL POLYETHYLENE OR APPROVED EQUAL.

SEE TAPPING SADDLE DETAIL (W-26)

- 1) METER SETTER WITH IDLER
- 2) N-16 UTILITY BOX WITH ALL METAL LID OR APPROVED EQUAL
- 3) WATER METER (PURCHASED THROUGH CITY)
- 4) CURB STOP
- 5) 4" DIA. RISER (NOTCHED OVER PIPE AT BASE)
- 6) 4" METER SPUD
- 7) 8 1/2" meter spud
- 8) SCH. 40 P.V.C. THROUGH PIPE EYE
- 9) 1/2" SCH. 40 PVC OR APPROVED EQUAL TO OTHER BOX (SEE DETAIL W-10)

D. Whitehead
 DERRICK WHITEHEAD
 ENVIRONMENTAL UTILITIES DIRECTOR



ENVIRONMENTAL UTILITIES
 DEPARTMENT

RESIDENTIAL 3/4" INCH
 SERVICE LINE

SCALE: NONE
 REVISED: MARCH 30, 2001
 DRAWN BY: R. VAN NESS
 APPROVED BY: D. WHITEHEAD

TYPICAL CROSS-SECTION OF METER INSTALLATION

CST
 W-5